



Vanguard Laboratory
 2635 Parkmont Lane SW
 Olympia, WA 98502
 360.967.7010

Report of Laboratory Analysis

Collected by:

Allen Hatten- Ken Lake

Sampling Address:

Lakemoor Community Club
 Ken Lake, WA

Matrix Drinking Water

Laboratory ID: V240618-12

Date Sampled: 6/18/24 16:00

Date Received: 6/18/24 17:00

Date Reported: 7/2/2024

Sample ID: **Main**

| Analysis | Result | SDRL | MCL | Units | DF | Date Analyzed |
|---|--------|------|-------|---------------------|----|---------------|
| Total Coliform & E. coli by SM 9223B (IDEXX) | | | | Batch ID:V240618-12 | | Analyst: AF |
| Fecal Coliforms | 33.6 | 1 | - | MPN/100 mL | 1 | 6/18/24 17:00 |
| Nitrate by EPA Method 353.2 | | | | Batch ID:V240618-12 | | Analyst: RK |
| Nitrate (as N) | ND | 0.50 | 10.00 | mg/L | 1 | 6/19/24 12:00 |
| Nitrite by EPA Method 354.1 | | | | Batch ID:V240618-12 | | Analyst: RK |
| Nitrite (as N) | ND | 0.10 | 1.00 | mg/L | 1 | 6/19/24 12:00 |
| Metals by EPA 200.8 | | | | Batch ID:V240618-12 | | Analyst: RK |
| Sulfur (as S) | ND | - | - | µg/L | 1 | 7/1/2024 |
| Phosphorus by HACH | | | | Batch ID:V240618-12 | | Analyst: RK |
| Phosphorus | ND | - | - | ppm | 1 | 7/1/2024 |

Notes:

MPN: Most Probable Number

ppm: parts per million

nd: non-detect

n/a: not applicable

SDRL: State Detection Reporting Limit

DF: Dilution Factor

MCL: Maximum Contaminant Level

Reviewed by Robert Smalling, Chemist on 07/02/2024

Approved by Tori Johnson, Operations Manager on 07/02/2024



Samples were received in acceptable condition. The result(s) in this report relate only to the portion of the sample(s) tested. All analyses were performed consistent with the Quality Assurance program of Vanguard Laboratory. Please contact the laboratory if you should have any questions about the results.



Vanguard Laboratory
 2635 Parkmont Lane SW
 Olympia, WA 98502
 360.967.7010

Report of Laboratory Analysis

Collected by:

Allen Hatten- Ken Lake

Sampling Address:

Lakemoor Community Club
 Ken Lake, WA

Matrix Drinking Water

Laboratory ID: V240618-12

Date Sampled: 6/18/24 16:00

Date Received: 6/18/24 17:00

Date Reported: 7/2/2024

Sample ID: **West**

| Analysis | Result | SDRL | MCL | Units | DF | Date Analyzed |
|---|--------|------|-------|---------------------|----|---------------|
| Total Coliform & E. coli by SM 9223B (IDEXX) | | | | Batch ID:V240618-12 | | Analyst: AF |
| Fecal Coliforms | 35.0 | 1 | - | MPN/100 mL | 1 | 6/18/24 17:00 |
| Nitrate by EPA Method 353.2 | | | | Batch ID:V240618-12 | | Analyst: RK |
| Nitrate (as N) | ND | 0.50 | 10.00 | mg/L | 1 | 6/19/24 12:00 |
| Nitrite by EPA Method 354.1 | | | | Batch ID:V240618-12 | | Analyst: RK |
| Nitrite (as N) | ND | 0.10 | 1.00 | mg/L | 1 | 6/19/24 12:00 |
| Metals by EPA 200.8 | | | | Batch ID:V240618-12 | | Analyst: RK |
| Sulfur (as S) | ND | - | - | µg/L | 1 | 7/1/2024 |
| Phosphorus by HACH | | | | Batch ID:V240618-12 | | Analyst: RK |
| Phosphorus | ND | - | - | ppm | 1 | 7/1/2024 |

Notes:

MPN: Most Probable Number

ppm: parts per million

nd: non-detect

n/a: not applicable

SDRL: State Detection Reporting Limit

DF: Dilution Factor

MCL: Maximum Contaminant Level

Reviewed by Robert Smalling, Chemist on 07/02/2024

Approved by Tori Johnson, Operations Manager on 07/02/2024



Samples were received in acceptable condition. The result(s) in this report relate only to the portion of the sample(s) tested. All analyses were performed consistent with the Quality Assurance program of Vanguard Laboratory. Please contact the laboratory if you should have any questions about the results.