



Vanguard Laboratory
2635 Parkmont Lane SW
Olympia, WA 98502
360.967.7010

Report of Laboratory Analysis

Collected by:

Allen Hatten - Ken Lake

Sampling Address:

Lakemoor Community Club
Ken Lake, WA 98501

Matrix Drinking Water

Laboratory ID: V250623-3

Date Sampled: 6/23/25 11:00

Date Received: 6/23/25 11:56

Date Reported: 6/25/2025

Sample ID: **Main Rec**

Analysis	Result	SDRL	MCL	Units	DF	Date Analyzed
Total Coliform & E. coli by SM 9223B (IDEXX)				Batch ID:V250623-3		Analyst: VJ
E. coli	3.1	1	-	MPN/100 mL	1	6/23/25 17:25
Fecal Coliforms	3.1	1	-	MPN/100 mL	1	6/23/25 17:25
Nitrate by EPA Method 353.2				Batch ID:V250623-3		Analyst: AF
Nitrate (as N)	ND	0.50	10.00	mg/L	1	6/23/25 17:00
Nitrite by EPA Method 354.1				Batch ID:V250623-3		Analyst: AF
Nitrite (as N)	ND	0.10	1.00	mg/L	1	6/23/25 17:00
Sulfate by HACH				Batch ID:V250623-3		Analyst: AF
Sulfate	ND	-	-	ppm	1	06/24/25 16:00
Phosphorus by HACH				Batch ID:V250623-3		Analyst: AF
Phosphorus	ND	-	-	ppm	1	06/24/25 16:00

Notes:

MPN: Most Probable Number

ppm: parts per million

nd: non-detect

n/a: not applicable

SDRL: State Detection Reporting Limit

DF: Dilution Factor

MCL: Maximum Contaminant Level

Reviewed by Dustin Newman, Laboratory Director on 06/23/2025

Approved by Tori Johnson, Operations Manager on 06/25/2025



Samples were received in acceptable condition. The result(s) in this report relate only to the portion of the sample(s) tested. All analyses were performed consistent with the Quality Assurance program of Vanguard Laboratory. Please contact the laboratory if you should have any questions about the results.